



## 28' H.M.A.C. PAVEMENT SECTION TYPICAL CROSS SECTION

NTS

- NOTES: \*
- LIME SHALL BE APPLIED AT 6 % BY WEIGHT MINIMUM QUANTITY IS 36#/SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
  - BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN. NO GREATER THAN 3:1 WITHOUT ARMORING.
  - FOR 30" GUTTER DETAIL, SEE CURB & GUTTER DETAILS.
  - CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 36#/SY.

REVISIONS	
REVISIONS	Revised 11/16/99 (Bar Size & Concrete Layer)
CITY OF ARLINGTON, TEXAS	
PROJECT NUMBER	
PROJECT NAME	
( PROJECT LIMITS )	
DATE:	SCALE: SHEET OF
DESIGNED BY:	DRAWN BY: CHECKED BY: